



SAM HOUSTON STATE UNIVERSITY
Huntsville, Texas 77341

ADDENDUM 1 for 753-2-WHT004

Invitation for Bid:

RE-ROOF PROJECT FOR VICK HOUSE AND SPIVEY HOUSE

The following are responses to questions or clarifications/corrections for the above referenced Invitation for Bid.

1. The following is an addition to the specifications:

Section 1-General, I Submittals, Subparagraph 4 was omitted by the Engineer. This subparagraph is as follows:

4. As a quality control measure, the prospective contractor shall include in the bid package statements of assurance that he has at least 10 years experience installing graveled foam roof systems and the proposed foam manufacturer stating that the foam formulation proposed for this project has been successfully used for gravel covered foam roofing systems for a least 10 years and warrantied by this same manufacturer for the same period, and complies with current regulations for blowing agent, outgassing, etc.
2. The alternate product proposed by Bundren Roofing, Inc. will not be accepted for this job.