

**PART 1: GENERAL**

1.01 Scope of Standard

- A. This standard provides general guidance concerning the specific preferences of SHSU for materials and products to prevent the spread of fire through openings in floors, walls and other building components.
- B. SHSU recognizes that project conditions and requirements vary, thus precluding the absolute adherence to the items identified herein in all cases. However, unless there is adequate written justification, it is expected that these guidelines will govern the design and specifications for SHSU projects.

1.02 Related Standards

- A. Compatibility of materials: All fire stopping must be a UL approved assembly.

1.03 Quality Control

- A. SHSU contact for review of fire-resistive assemblies: State Fire Marshall.
- B. For all remodels and renovations contractor shall maintain integrity of existing fire barriers.

1.04 General Requirements

- A. Labeling/identifying conditions for future modifications: On the above ceiling (concealed) surface of each side of all fire rated walls, stencil in red and with 6" lettering, the rating of the wall. Labeling of each fire rated penetration above ceiling by a certified company is required.
- B. This labeling shall occur at 10' intervals.  
  
Each UL Listed system shall be documented with locations on As Built drawings.
- C. Asbestos: In no instance will any product containing asbestos be acceptable for use.
- D. Fire Stopping assemblies must make a smoke tight and water tight seal.

**PART 2: PRODUCTS - NOT USED PART 3:**

**EXECUTION - NOT USED**

END OF STANDARD 07840